

EU DECLARATION OF CONFORMITY

We the manufacturer: **Palmstierna International AB** and **PMV Automation AB**, Korta Gatan 9, SE-171 54 Solna, under sole responsibility declare that the product,

Digital Valve Positioner (D3)

is in conformity with the following harmonised legislation:

Directive: **2014/30/EU (EMC)**

Applied Standards: **EN 61000-6-2, 3 and 4**

Directive: **2014/35/EU (Low Voltage Directory)**

Applied Standards: **EN 60204-1, IEC 61010-1**

Directive: **2014/34/EU (ATEX)**

Applied Standards, Ex db/tb: **EN 60079-0:2012/A11:2013 (EN IEC 60079-0:2018)***

EN 60079-1:2014

EN 60079-31:2014

Applied Standards, Ex ia: **EN 60079-0:2009 (EN IEC 60079-0:2018)***

EN 60079-11:2007 (EN 60079-11:2012)*



EN 60079-26:2007 (EN 60079-26:2015)*

** A review between standards used during certification and the harmonized standards (in parenthesis) have identified no significant change relevant for the construction and commissioning of this product.*

Quality Assurance: **Nemko, P.O.Box 73 Blindern, N-0314 Oslo, Norway**

Notified body, Ex db/tb: **DNV GL Nemko Presafe AS, Veritasveien 3, 1363 Høvik, Norway**

Notified body, Ex ia: **Nemko, P.O.Box 73 Blindern, N-0314 Oslo, Norway**

Product marking :	EU-type examination Certificate	Model code (x=any character)
 II 1G Ex ia IIC T4 Ga Ta:80°C FISCO Field Device	Nemko 03ATEX110X	D3lxx-xxxxxx-xxxx D3Yxx-xxxxxx-xxxx
 II 2G Ex db IIB+H2 T6 -20°C ≤ Ta ≤ +60°C. II 2D Ex tb IIIC T100°C -20°C ≤ Ta ≤ +80°C	Presafe 17 ATEX 11598X	D3Exx-xxxxxx-xxxx D3Fxx-xxxxxx-xxxx

Authorized Person for the manufacturer



Mikael Ekman
Site Manager
Solna, Sweden